



Paraseal LG target sheet to be secured with nails and washers at the corners with box staples located at 3" O.C. thereafter.

Seal TREMDrain core around full perimeter of pipe using Vulkem 116, Dymonic 100 or TREMproof 250 GC - T

Parastick N Dry or Superstop Waterstop wrapped around pipe, pressed against target sheet, and wire tied into place.

Paramastic cant' fill

Lagging/Shoring/Permanent form

TREMDrain 1000 as specified

Concrete or shotcrete wall

Paraseal LG 20 mil with Bentonite side facing installer.

NOTE: Paraseal products require a min of 24 PSF of compaction/confinement in order to function as designed.

| | | | | | | |
|--|---|--------------|----------------|---------------|-----------------|-------------------|
| TREMCO www.tremcosealants.com 3735 Green Road * Beachwood, OH 44122 Phone : 866-209-2404 * Fax: 216-766-5535 | Detail: BLINDSIDE WALL PIPE PENETRATION | | | Sheet Number: | File Name: | Rev # |
| | This detail is intended for conceptual purposes only. | Drawn by: MI | Checked by: JM | Scale: None | Date: 5/24/2016 | BSW-29-LG20 00 |